

Office of Public Safety

Department of Justice and Public Safety

Provincial Fire Marshal

PO Box 2000 Charlottetown Prince Edward Island Canada C1A 7N8

Tel: 902 368-4869 Fax:902 368-5526



May 16, 2024

To ensure the safety of patrons and vendors during the Cavendish Beach Music Festival, the Fire Marshal's Office has created the below checklist for vendors to follow. Non-compliance with the items sited in the checklist will result in a suspension of that vendors operations during the event.

Cavendish Beach Music Festival Vendor Checklist:

	Grill(s) and/or deep fryer(s) [any appliance creating grease laden vapours] shall be located in a structure or trailer (no tents) with Fire Suppression and Ventilation installed in accordance with NFPA 96.
	Fire Suppression systems shall be certified (annually tagged).
	All propane installations shall meet CSA B149.2 Code, be inspected by the Propane Inspector (Inspection Services) and tanks shall be installed on a solid base and fastened securely to the trailer or structure.
	Two additional fire extinguishers (min 10 lb ABC and Class K) shall be located in all commercial cooking facilities that produce grease laden vapours and same shall be certified (annually tagged).
	Tents within the venue (food and beverage service, general assembly, merchandise, etc.) shall meet NFPA 102 & 701 and display the code appropriate tag. They shall also be equipped with the necessary 10 lb ABC fire extinguisher(s). <i>This includes awnings attached to vendors vehicles/trailers</i> .
	All propane cylinders shall be stored in a central secure location protected from vehicle traffic, and all tanks shall be marked with vendors name.
	Propane BBQ's shall not be located under or near combustible materials, this shall include awnings and tents.
	All Flammable liquids shall be stored in a central secure location.
	The use of individual electric generators shall only be permitted as a backup power source in the event of a power outage.
A final pre-event site inspection will be completed on	